

M.O.M.

Date: 03.09.2022

M/s Vital Laboratories Pvt Ltd, Unit II
Mr. Rohit Singh
Mr. Sanvarjeet Sharma
Mr. Kelvin Patel
Mr. Shankar Bajaj

M/s Everest Blower System Pvt. Ltd.
Mr. Prerak Bhatt

Process details

Reactor cap – 5 KL in SS 316

Condenser -8 m² single pass shell and tube type

Receiver – 500 L, Vacuum catch pot – 500 L

Batch process, 60 Hrs total batch time

Up to 30 deg C vacuum applies (cooling is done by means of recovering hot water vapours)

95 deg C to 50 deg C, – working on only water jet with 12.5 HP motor with or without air bleed

50 deg C to 30 deg C, working on water jet with 12.5 HP motor + two stage steam ejector

Product – Cinchonce, Reactor No. 12304, Capacity – 5 kL, MOC – SS

Parameters	
Total System Volume (m ³):	8 KL
pH of carry overload	Neutral
Number / size of pre-condensers & utility used in them:	1 no. 8 m ² having chilled/cooling water utility available
Vacuum required in process:	Initially very low 500 torr abs with some air bleed and at final stage 750-755 torr abs
Air leakage (kg/h): optional	Max 4 kg/hr
Condensable vapour load at pump suction (kg/h) [vapours escaping condenser]:	Max 20 kg/hr
Name, and molecular weight of solvents /resin used:	Water
Any Chances of solid particles coming inside the pump	No
Temperature of vapor entering the pump after pre-condensers:	Max 50 deg C

Batch trial done for BARK process at Plot 2208 on 02-09-2022 & observations are as follows: -

1. Achieved 51.2 deg C using water jet of 12.5 HP motor.
2. From 51.2 deg C started Everest dry vacuum pump with 7 HP consumed power at 1:33 pm
3. Achieved 30 deg C at 8:00 pm after that vacuum system shut down.
4. Achieved 21 deg C temperature decrease in 6:30 hours.

Conclusion: -

Achieved required temperature in time less than or equal to time taken by steam ejector

Below is direct and indirect savings

PLEASE FILL THE GREEN HIGHLIGHTED CELLS.			
Parameters	UoM	Steam Ejectors	Everest 300 m3/hr Dry Screw Pump
Operating Hours	Hours/Day	24	24
	Days/Month	25	25
	Months/Year	12	12
	Hours/Year	7,200 /	7,200
Gas consumption to generate Steam Consumption			
Flow Rate	kg/h	58	0
Steam Cost	Rs./kg	₹ 2.5	₹ 2.5
	Rs./h	₹ 145	₹ 0
	Rs./Year	₹ 10,44,000	₹ 0
Power Consumed			
Consumed Units	kW	9.30	5.25
Power Cost	Rs./kWh	₹ 7.5	₹ 7.5
	Rs./h	₹ 69.8	₹ 39.38
	Rs./Year	₹ 5,02,200	₹ 2,83,500
Overall Costs			
Total Operating Cost	Rs./h	₹ 214.8	₹ 39.4
	Rs./Year	₹ 15,46,200	₹ 2,83,500
Maintenance Cost	Rs./Year	₹ 20,000	₹ 30,000
Annual Operating Cost	Rs./Year	₹ 15,66,200	₹ 3,13,500
Annual Savings	Rs./Year	₹ 12,52,700	
INDIRECT SAVINGS			
No pollution.			
Consistent vacuum levels.			

Relativ
03/09/2022

[Signature]
03/09/2022

[Signature]
03/09/2022